



Sheriff's Office Fire System Upgrades

Addendum #1 - Questions and Answers

1. On Friday October 24 Edwards announced the discontinuation of the 3-SSDC1 and the SDDC1 Signature Driver Modules. The replacement driver module part numbers are 4-SSDC1 and 4-SDDC1. All Signature driver modules should be replaced. **Yes, all outdated modules should be replaced.**
2. On September 1, 2025, Edwards announced the discontinuation of the 3-MODCOM communications module. The replacement model is EST4 Gateway. The existing 3-MODCOM should be replaced. **Yes, please replace the module.**
3. During the walkthrough it was discovered that the existing batteries have exceeded their replacement dates. Are new batteries to be included in the proposal. **Yes.**
4. The EST-4 components may have a higher current draw than the obsolete components. Are we to provide updated battery calculations and battery upsize if required? **No, all panels are on generator power.**